



## **FILTERS**

### **Standard Filter Replacement Intervals**

PHSI (Pure Health Solution Incorporated) equipment is certified as a system. The systems performance is dependent upon timely filter replacements with PHSI certified products.

Think Healthy Systems is committed to providing our customers with the purest, drinking water possible. In order to deliver on this promise, all PHSI Pure Water Technology equipment will be maintained as follows:

<i>Filter</i>	<i>Minimum Replacement Interval</i>
Sediment	12 months or 1,500 gallons (whichever occurs first)
Pre-Carbon	12 months or 1,500 gallons (whichever occurs first)
R.O.	3-5 years
Post-Carbon	24 months or 2,000 gallons



### **Data Management**

All filter replacements will be logged for case history – Maintenance History Reports can be provided anytime by request.

*Note: Water with excessive degrees of sediment, may require more frequent filter changes.*